

Government of Bihar


Public Health Engineering Department

District Level Water Testing Laboratory:- Siwan

Sample Collected by- Divine Public School

Sample Receiving date:-16.08.2026

1	Date Of Testing	Block	Panchyat	Name of School	Parameters														
					pH	Turb.	EC	TDS	TH	Ca	Mg	Cl	Alka.	Fe	NO ₃	SO ₄	F	As	Total Coli
1	17.08.2026	Raghunathpur	Phulwariya	Divine Public School, Phulwariya	7.11	0.8	-	289	115.6	21.90	10.4	19.50	102.30	0.22	BDL	10	0.29	0.00	<1.1
IS: 10500:2012 (2nd Revision)			Accetable Limit		6.5-	1.0	-	500	200	75	30	250	200	1.0	45	200	1.0	0.01	
			Permissible Limits		8.5	5.0	-	200	600	200	100	1000	600	NR	NR	400	1.5	NR	


Chemist
P.H. Division, Siwan
District Water Testing Lab
PHED Siwan